



Notice Inviting Tender

Sealed tenders are invited on behalf of Chairman & CEO; Noida SEZ Authority for the following works in NSEZ. Phase – II, Noida, Distt. Gautam Budh Nagar from Public Sector Undertakings/Autonomous Organizations/ registered contractors on or before 15.6.10 up to 3.00 P.M. and the same shall be opened on the same day at 3.30 P.M. in the conference hall of NSEZ Phase- II, Noida. Earnest Money is required in the shape of DD from any Scheduled Bank in favour of “Noida SEZ Authority”. The same shall be enclosed with techno commercial details

Tender documents shall be available for sale at the reception counter of the Office of the Development Commissioner, NSEZ, Noida w.e.f. 28.5.10 on all working days during 10.00 am to 5.00 pm.

The tender shall be on two bid system, where techno-commercial details shall be put into envelope No. (1) & price bid shall be put in the envelope No. (2) Both these envelopes after being sealed properly shall be put in to envelope No (3) which should be properly sealed, before it is put in to the tender box. Envelope No (1) shall contain all details about experience, qualification documents, income tax clearance, etc as required. Tender of contractors who do not qualify the pre-qualifications (as mentioned in the tender documents) shall be summarily rejected and their price bids shall not be opened. Authority can reject any or all-tenders without assigning any reasons.

S. No.	Scope of the Work	Estimated Cost of work (Rs. in Lacs)	Cost of Tender (In Rs.)	Earnest Money (In Rs.)	Time of Completion
1.	Connectivity of water line for Fire Safety from SDF J&K blocks to SDF- F,G,H&I blocks (Details may be seen in tender documents)	15.00	1000/-	1.5 lacs	3 months

Contd.- 2-

-2-

Scope of Work

S.No.	Description	Qty.	Unit
1.	<p>FIRE HYDRANT SYSTEM OF BLACK STEEL Providing fixing and Testing pipe to IS: 1239 (Heavy Class M.S. "C") including all fittings like standard mild steel flanges screwed for weeded gasket, nuts, bolts, anchor fasteners coupling, bands elbows, tees etc. welded or screwed joints as required, cutting holes and painting pipe and fitting with two more coat synthetic enamel and shade over a coat of ready mixed red led primer or wrapping coating for underground pipe with breaking of RRC Road.</p> <p>MAKE : JINDAL/TT SWASTIK</p>		
(a)	150mm dia	114	Mtrs.
(b)	100mm dia	804	Mtrs.
©	80mm dia	60	Mtrs.
2.	<p>Providing fixing and Testing of gun hydrants valve single headed internal outlet on each floor complete with 63mm dia female instantaneous double outlet of with black cap and chain as per IS : 5290.</p> <p>MAKE : NEWAGE/VIJAY SUPER</p>	55	Nos.
3.	<p>Providing fixing and Testing of 63mm dia 15 Mtr. Long reinforced rubber lined hose pipe complete with coupling as per IS: 636.</p> <p>MAKE : NEWAGE/CRC/PADMINI</p>	55	Nos.
4.	<p>Providing and fixing of 63mm dia instantaneous patter short branch pipe of gun metal with 63mm dia male and female and 16mm dia bore of nozzle confirming to IS : 903 for connection as required.</p> <p>MAKE : NEWAGE/SUPPER</p>	55	Nos.
5.	<p>Providing fixing and testing of first aid hose-reel swinging type with 30mtr. Lengths 20mm dia rubber lines hose with 25mm dia globe valve terminating with ABS plastic nozzle of 6.25mm dia complete with drum and suitable bracket etc. as required as per IS: 884 with 07Kg. tested pressure.</p>		

	MAKE : NEWAGE/SUPPER	20	Nos.
6.	Providing fixing and testing of fire hose cabinet fabricated from MS sheet fully welded construction with hinged double front door with locking arrangement partially glazed with 4mm thick glass, stove enameled fire red finish with " Fire Hose " written on front suitable to hose 2 Nos. 15 Mtrs. Canvas hoses with coupling one branch pipes.	15	Nos.
7.	Providing fixing and testing of 20mmx30Mtr. Long rubber pipe for hose reel. MAKE : JYOTI	20	Nos.
8.	Providing fixing and testing of hose reel nozzle.	20	Nos.
9.	Providing fixing and testing of glass for hose cabinet.	40	Pcs.
10.	Providing fixing and testing of sluice valve size of. MAKE : KILOSKER		
(a)	100mm dia	8	Nos.
(b)	150mm dia	02	Nos.
11.	Providing fixing and testing of fire brigade inlet connection comprising of 63mm dia gun metal instantaneous male inlet coupling with plug and top chain as required.		
(a)	Two way FBC	08	Nos.
(b)	Four way FBC	02	Nos.
12.	Providing fixing and testing of pressure gauge.	04	Nos.
13.	Providing, fixing and testing of butterfly valve.		
(a)	100mm dia		
(b)	150mm dia	02	Nos.
14.	Providing, fixing & testing of pressure switch for automatic operations.	04	Nos.
15.	Repairing, fixing & testing of fire hose cabinet door.	40	Nos.
16.	Repairing & testing of automatic control panel for the terrace pump.	02	Set